



Italia

Scegli la certezza.  
Aggiungi valore.

## FIRE SAFE TEST CERTIFICATE

FLOATING BALL VALVE WAFER

Size 2"

Class 150 LBS

Drawing: Y\_1266

CERTIFICATE NUMBER: IS-197256-01-09

CLIENT: OMAL S.p.a.  
ADDRESS: Via Ponte Nuovo, 11  
25050 RODENGO SAIANO (BS)

REPORT NUMBER: 1154

SCOPE OF REPORT: Fire Safe test carried out according to:  
API 6FA par. 4.8.1 and 4.8.2 – Third Edition April 1999

max BAR: 14.5

max °C : 905

CERTIFICATION  
EXPIRED DATE: 12 October 2012



CERTIFICATION DATE

13/10/2009



TÜV ITALIA S.R.L.  
TÜV SÜD Group

Direzione e Sede Amministrativa:  
Via Giosué Carducci, 125 edificio 23  
20099 Sesto San Giovanni (MI)  
Sede legale: Via Mauro Macchi, 27 20124 Milano  
Società soggetta al controllo e al coordinamento di  
TÜV SÜD AG

Telefono: +39 02 24130.1  
Telefax: +39 02 24130.399

www.tuv.it

Amministratore Delegato:  
Ing. Andrea Vivi

Registro delle imprese di Milano  
n. iscrizione e Cod. Fisc. 08922920155  
R.E.A. 1255140 - P. IVA 02055510966  
Capitale sociale: Euro 500.000 int. vers.  
Coord. Bancarie: INTESA BCI - CIN J  
c/c 000018978166 - ABI 03069 - CAB 32934  
IBAN: IT34 J030 6932 9340 0001 8978 166