



Scegli la certezza.
Aggiungi valore.

FIRE SAFE CERTIFICATE

CERTIFICATE NUMBER: **FS-063579-556**

CLIENT: **OMAL**
ADDRESS: **Via Ponte Nuovo, 11 25050 Rodengo Saiano (BS) - Italy**

REPORT NUMBER: **28**

SCOPE OF REPORT: Fire Safe test carried out according to: **ISO 10497 Third Edition February 2010 and API 607 Sixth Edition September 2010**

max BAR: **40,0 Bar**

max °C: **+934°C**

QUALIFIED VALVE: Size: DN 50
Rating Class: PN 40
Drawing N°: Y_4112
Type: FLOATING BALL VALVE SPLIT BODY

RANGE AND TYPE OF VALVES COVERED: DN 50 and below 65, 80, 100 (NPS 2" and below 2".1/2, 3", 4")
PN 40, 63, 100 (Class 300; 400; 600)

TÜV
INSPECTOR
Mastrogiacomo Simone

	☐ Review
	☒ Witness
Date: 13/03/15	Name:

CERTIFICATION DATE
13/03/2015

MANAGEMENT INSPECTION
SERVICE
Frecchiami Mauro

