

C E R T I F I C A T E

This certifies, that the company

Omal S.p.A.
Via Ponte Nuovo, 11
25050 Rodengo Saiano (BS)
Italy

Is authorized to provide the product mentioned below

Description of product: **Split body floating ball valve series Prochemie**

In accordance with: **EN 61508:2010 Parts 1, 2, 3, 4, 5, 6, 7**

Registration No 21 22135 01
Test Report No PS-22135-21-L
File reference 22135-01



TÜV NORD Italia S.r.l. (TÜV NORD Group)
Via Turati, 70 20023 Cerro Maggiore (MI)



www.tuev-nord.it

Validity
from 2021-11-22
until 2024-11-22

Cerro Maggiore, 2021-11-22
prodotto@tuev-nord.it

Please also pay attention to the information stated overleaf

TNI-QF(IND-SIL-01)-14-Rev00_01_03_2020-Certificate_Type A

ANNEX

Annex 1, Page 2 of 2

To Certificate-Nr. 21 22135 01

Type	A
HFT	0
Safety functions	1. Close / Open upon the demand of the actuation system 2. Close upon the demand of the actuation system, with inline tightness when in closed position
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
Series Prochemie - No PST	1	1,25E-08	0,00E+00	0,00E+00
Series Prochemie - With PST	1	1,12E-09	1,14E-08	0,00E+00
Series Prochemie - No PST	2	1,71E-08	0,00E+00	0,00E+00
Series Prochemie - With PST	2	5,75E-09	1,14E-08	0,00E+00

Systematic capability	3 (Route 1 _s applied)			
Architectural constraints	Route 1_H:	Applied	Route 2_H:	Applied
	The product can be used in: <ul style="list-style-type: none"> • single channel configuration: <ul style="list-style-type: none"> ○ up to SIL 2 without external diagnostic tests ○ up to SIL 3 considering external diagnostic tests • double channel configuration: up to SIL 3 			
Remarks:	<ul style="list-style-type: none"> • For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SMA201802. 			

