



Italia

Scegli la certezza.  
Aggiungi valore.

## FIRE SAFE TEST CERTIFICATE

FLOATING BALL VALVE WAFER

Size 2"

Class 150 LBS

Drawing: Y\_1266

CERTIFICATE NUMBER: IS-197256-01-09

CLIENT: OMAL S.p.a.  
ADDRESS: Via Ponte Nuovo, 11  
25050 RODENGO SAIANO (BS)

REPORT NUMBER: 1154

SCOPE OF REPORT: Fire Safe test carried out according to:  
API 6FA par. 4.8.1 and 4.8.2 – Third Edition April 1999

max BAR: 14.5

max °C : 905

CERTIFICATION EXPIRED DATE: 12 October 2012



CERTIFICATION DATE  
13/10/2009



TÜV ITALIA S.R.L.  
TÜV SÜD Group

Direzione e Sede Amministrativa:  
Via Giosué Carducci, 125 edificio 23  
20099 Sesto San Giovanni (MI)  
Sede legale: Via Mauro Macchi, 27 20124 Milano  
Società soggetta al controllo e al coordinamento di  
TÜV SÜD AG

Telefono: +39 02 24130.1  
Telefax: +39 02 24130.399

www.tuv.it

Amministratore Delegato:  
Ing. Andrea Vivi

Registro delle imprese di Milano  
n. iscrizione e Cod. Fisc. 08922920155  
R.E.A. 1255140 - P. IVA 02055510966  
Capitale sociale : Euro 500.000 int. vers.  
Coord. Bancarie: INTESA BCI - CIN J  
c/c 000018978166 - ABI 03069 - CAB 32934  
IBAN: IT34 J030 6932 9340 0001 8978 166

TÜV ITALIA S.R.L.  
 TÜV SÜD Group  
 Via Giosuè Carducci, 125 edificio 23  
 20099 Sesto San Giovanni (MI)  
 Telefono: +39 02 24130.1  
 Telefax: +39 02 24130.399  
 www.tuv.it



Italia

<b>FIRE SAFE TECHNICAL REPORT</b>
<b>FIRE SAVE CERTIFICATE N°: IS-197256-01-09</b>
<b>CLIENT DOSSIER N°: 1154</b>

<u>CLIENT:</u>	<b>OMAL S.p.a.</b>
<u>ADDRESS:</u>	<b>Via Ponte Nuovo, 11 25050 RODENGO SAIANO (BS)</b>

<b>QUALIFIED VALVE</b>	
<u>VALVE SIZE:</u>	<b>2"</b>
<u>VALVE RATING CLASS:</u>	<b>150 LBS</b>
<u>DRAWING N°:</u>	<b>Y_1266</b>
<u>VALVE TYPE:</u>	<b>FLOATING BALL VALVE WAFER</b>
<u>MAX BAR:</u>	<b>14.5</b>
<u>MAX °C:</u>	<b>905</b>

<u>RANGE AND TYPE OF VALVES COVERED:</u>	<b>Size 2" and 2"1/2, 3", 4"</b>
<u>MODEL:</u>	<b>Class #150/300 LBS    DN 50, 65, 80, 100 580-581/ 480-481</b>

<b>THE ABOVE MENTIONED VALVE SUCCESSFULLY PASSED THE FIRE SAFE IN ACCORDANCE TO:</b>	
	<b>API 6FA par. 4.8.1 and 4.8.2 – Third Edition April 1999</b>

<u>NOTES:</u>	
<u>LOCATION AND DATE OF TEST CARRIED OUT:</u>	<b>OMAL S.p.a. 13/10/2009</b>

**TÜV** TÜV  Review  
 ITALIAN INSPECTOR  Witness  
 Date: 13/10/09 Name: *[Signature]*