



Italia

Scegli la certezza.
Aggiungi valore.

FIRE SAFE TEST CERTIFICATE

FLOATING BALL VALVE SPLIT WAFER

Size: 2"
Class: 150 LBS
Drawing: Y_1440

CERTIFICATE NUMBER: FS-063579-027

CLIENT: OMAL S.p.A.
ADDRESS: Via Ponte Nuovo, 11
25050 Rodengo Saiano (BS) Italy

REPORT NUMBER: 1174

SCOPE OF REPORT: Fire Safe test carried out according to:
API 6FA Third Edition April 1999

For further details of test arrangements and test results , see REPORT OF
FIRE TEST No. 1174 herewith attached and duly endorsed

TÜV
INSPECTOR

CERTIFICATION DATE

MANAGEMENT OF INSPECTION
SERVICE

	<input type="checkbox"/> Review
Date: 16/09/10	<input checked="" type="checkbox"/> Witness
Name: <i>PS</i>	

16/09/2010



TÜV ITALIA S.R.L.
TÜV SÜD Group

Telefono: +39 02 24130.1
Telefax: +39 02 24130.399

Amministratore Delegato:
Roberto Majocchi

Direzione e Sede Amministrativa:
Via Giosuè Carducci, 125 edificio 23
20099 Sesto San Giovanni (MI)
Sede legale: Via Mauro Macchi, 27 20124 Milano
Società soggetta al controllo e al coordinamento di
TÜV SÜD AG

www.tuv.it

Registro delle imprese di Milano
n. iscrizione e Cod. Fisc. 08922920155
R.E.A. 1255140 - P. IVA 02055510966
Capitale sociale : Euro 500.000 int. vers.
Coord. Bancarie: INTESA BCI - CIN J
c/c 000018978166 - ABI 03069 - CAB 32934
IBAN: IT34 J030 6932 9340 0001 8978 166

TÜV ITALIA S.R.L.
TÜV SÜD Group
Via Giosuè Carducci, 125 edificio 23
20099 Sesto San Giovanni (MI)
Telefono: +39 02 24130.1
Telefax: +39 02 24130.399
www.tuv.it



Italia

FIRE SAFE TECHNICAL REPORT

FIRE SAFE CERTIFICATE N°: FS-063579-027

CLIENT DOSSIER N°: 1174

CLIENT: OMAL S.p.A.
ADDRESS: Via Ponte Nuovo, 11
25050 Rodengo Saiano (BS) Italy

QUALIFIED VALVE

<u>VALVE SIZE:</u>	2"
<u>VALVE RATING CLASS:</u>	150 LBS
<u>DRAWING N°:</u>	Y_1440
<u>VALVE TIPE:</u>	FLOATING BALL VALVE SPLIT WAFER

For further details of test arrangements and test results , see REPORT OF FIRE TEST No. 1174 herewith attached and duly endorsed

RANGE AND TYPE OF VALVES COVERED: Size 2"; 2"½ ; 3"; 4" DN 50; 65; 80; 100
Class #150; #300

THE ABOVE MENTIONED VALVE SUCCESSFULLY PASSED THE FIRE SAFE IN ACCORDANCE TO:

API 6FA Third Edition April 1999

NOTES:

LOCATION AND DATE OF TEST CARRIED OUT: OMAL; 16/09/2010

TÜV
INSPECTOR

