



Italia

Scegli la certezza.  
Aggiungi valore.

## FIRE SAFE CERTIFICATE

CERTIFICATE NUMBER: FS-063579-227

CLIENT: OMAL  
ADDRESS: Via Ponte Nuovo, 11  
25050 Rodengo Saiano (BS)- Italy

REPORT NUMBER: 1252

SCOPE OF REPORT: Fire Safe test carried out according to: **API 607 Sixth Edition September 2010, ISO 10497 Third Edition September 2010**

max BAR: **14,3 Bar**

max °C: **+922°C**

QUALIFIED VALVE:

Size:	3"
Rating Class:	150
Drawing N°:	Y_2151
Model:	V470-V471/VT1 (THOR)
Type:	FLOATING BALL VALVE SPLIT BODY

**NOTE:** In according to 7.2.2 if a range of valves covered by testing of ferritic test valve (see fire safe cert. n°FS-063579-024 / our test report n°1180 and fire safe certificate n°FS-063579-30 / our test report n°1181), then the type-testing coverage may be extended to cover austenitic or duplex materials by carrying out a further test on a mid-range size of a valves of the same design and material.

RANGE AND TYPE OF VALVES COVERED: NPS All size from ½" to 8" (DN 50 all size from 15 to 200)  
Class 150; 300 (PN 10, 16, 25, 40)



Frecchiami Mauro

CERTIFICATION DATE  
11/02/13

