



Italia

CERTIFICATO_FS
09/01/2007

Scegli la certezza.
Aggiungi valore.

FIRE SAFE CERTIFICATE

CERTIFICATE NUMBER: **FS-063579-184**

CLIENT: **OMAL**
ADDRESS: **Via Ponte Nuovo, 11
25050 Rodengo Saiano (BS)- Italy**

REPORT NUMBER: **1231**

SCOPE OF REPORT: Fire Safe test carried out according to:
API 607 Sixth Edition September 2010 and EN ISO 10497 Third Edition February 2010

max BAR: **46,3 Bar**

max °C: **+920°C**

TÜV
INSPECTOR

Mastrogiacomone Simone

	☐ Review
	☒ Witness
Date: 03/12/12 Name:	

TÜV ITALIA S.R.L.
TÜV SÜD Group

Direzione e Sede Amministrativa:
Via Giosuè Carducci, 125 edificio 23
20099 Sesto San Giovanni (MI)
Sede legale: Via Mauro Macchi, 27 20124 Milano
Società soggetta al controllo e al coordinamento di
TÜV SÜD AG

Telefono:
Telefax:

www.tuv.it

TÜV®

CERTIFICATION DATE
03/12/2012

Amministratore Delegato:
Andrea Vivi

MANAGEMENT OF INSPECTION
SERVICE

Mastrogiacomone Simone



Registro delle imprese di Milano
n. iscrizione e Cod. Fisc. 08922920155
R.E.A.: 1255140 - P. IVA 02055510966
Cod. Identificazione CEE IT 02055510966
Capitale sociale : Euro 500.000 int. Vers.
INTESA SAN PAOLO S.p.A. BIC: BCITIT33378
IBAN: IT34 J030 6932 9340 0001 8978 166

TÜV ITALIA S.R.L.
TÜV SÜD Group
Via Giosuè Carducci, 125 edificio 23
20099 Sesto San Giovanni (MI)
Telefono: +39 02 24130.1
Telefax: +39 02 24130.399
www.tuv.it



FIRE SAFE TECHNICAL REPORT

FIRE SAFE CERTIFICATE N°: FS-063579-184

CLIENT DOSSIER N°: 1231

CLIENT: OMAL
ADDRESS: Via Ponte Nuovo, 11
25050 Rodengo Saiano (BS)- Italy

QUALIFIED VALVE

<u>VALVE SIZE:</u>	2"
<u>VALVE RATING CLASS:</u>	300 lbs
<u>MODEL:</u>	V472/VT1
<u>DRAWING N°:</u>	Y_2083
<u>VALVE TYPE:</u>	Floating Ball Valve Split Body (FB&RB)
<u>MAX BAR:</u>	46,3 BAR
<u>MAX °C:</u>	+920°C

RANGE AND TYPE OF VALVES COVERED: NPS 2"; 2".1/2; 3"; 4" (DN 50; 65; 80; 100)
Class 300; 600 (PN 63; 100)

THE ABOVE MENTIONED VALVE SUCCESSFULLY PASSED THE FIRE SAFE IN ACCORDANCE TO:

API 607 Sixth Edition September 2010 and EN ISO 10497
Third Edition February 2010

NOTES:

<u>LOCATION AND DATE OF</u>	OMAL
<u>TEST CARRIED OUT:</u>	Rodengo Saiano (BS) - Italy 03/12/2012

TÜV
INSPECTOR
Mastrogiacomo Simone

