



Italia

Scegli la certezza.  
Aggiungi valore.

## FIRE SAFE CERTIFICATE

CERTIFICATE NUMBER: **FS-063579-400**

CLIENT: **OMAL**  
ADDRESS: **Via Ponte Nuovo, 11 25050 Rodengo Saiano (BS)- Italy**

REPORT NUMBER: **15**

SCOPE OF REPORT: Fire Safe test carried out according to: **ISO 10497 Third Edition FEBRUARY 2010 and API 607 Sixth Edition SEPTEMBER 2010**


max BAR: **12 Bar**

max °C: **+866°C**

QUALIFIED VALVE: Size: 2"  
Rating Class: PN 16  
Drawing N°: Y\_2931  
Type: FLOATING BALL VALVE WAFER TYPE

RANGE AND TYPE OF VALVES COVERED: NPS 2" and below 2.1/2"; 3"; 4" (DN 50 and below 65, 80, 100)  
Class 150 (PN 16, 25).

TÜV  
INSPECTOR  
Frecchiami Mauro



CERTIFICATION DATE  
09/04/2014

MANAGEMENT INSPECTION  
SERVICE  
Mastrogiacomo Simone

