



Italia

Scegli la certezza.
Aggiungi valore.

FIRE SAFE CERTIFICATE

CERTIFICATE NUMBER: **FS-063579-402**

CLIENT: **OMAL**
ADDRESS: **Via Ponte Nuovo, 11 25050 Rodengo Saiano (BS)- Italy**

REPORT NUMBER: **17**

SCOPE OF REPORT: Fire Safe test carried out according to: **ISO 10497 Third Edition FEBRUARY 2010 and API 607 Sixth Edition SEPTEMBER 2010**

max BAR: **29,4 Bar**

max °C: **+872°C**

QUALIFIED VALVE: Size: 2"
Rating Class: PN 40
Drawing N°: Y_2759
Type: FLOATING BALL VALVE WAFER TYPE

RANGE AND TYPE OF VALVES COVERED: NPS 2" and below 2.1/2"; 3"; 4" (DN 50 and below 65, 80, 100)
Class 300 (PN 40)

TÜV
INSPECTOR
Frecchiamini Mauro



CERTIFICATION DATE
10/04/2014

MANAGEMENT INSPECTION
SERVICE
Mastrogiacomo Simone

