

FIRE SAFE CERTIFICATE

CERTIFICATE NUMBER:

FS-063579-398

CLIENT:

OMAL

ADDRESS:

Via Ponte Nuovo, 11 25050 Rodengo Saiano (BS)- Italy

REPORT NUMBER:

13

SCOPE OF REPORT:

Fire Safe test carried out according to: ISO 10497 Third Edition FEBRUARY 2010 and API 607 Sixth Edition SEPTEMBER 2010

max BAR:

14,3 Bar

max °C:

+871°C

QUALIFIED VALVE:

Size:

Rating Class: Drawing N°:

ANSI 150 Y_2930

Type:

FLOATING BALL VALVE SPLIT BODY

RANGE AND TYPE OF NPS 2" and below 2.1/2"; 3"; 4" (DN 50 and below 65, 80, 100)

VALVES COVERED: Class 150; 300 (PN 10, 16, 25, 40).

TÜV **INSPECTOR** Frecchiami Mauro

Review

CERTIFICATION DATE 04/04/2014

MANAGEMENT INSPECTION SERVICE Mastrogiacomo Simone

talla.