



Italia

Scegli la certezza.
Aggiungi valore.

FIRE SAFE CERTIFICATE

CERTIFICATE NUMBER: FS-063579-319

CLIENT: OMAL
ADDRESS: Via Ponte Nuovo, 11
25050 Rodengo Saiano (BS)- Italy

REPORT NUMBER: 03

SCOPE OF REPORT: Fire Safe test carried out according to: **API 607 Sixth Edition September 2010, ISO 10497 Third Edition February 2010**

max BAR: 14,7 Bar


max °C: +930,5°C

QUALIFIED VALVE:
Size: 6"
Rating Class: 150
Drawing N° Y_2504
Model: SUPREME
Type: TRUNNION BALL VALVE SPLIT BODY

RANGE AND TYPE OF VALVES COVERED: NPS 6", 8", 10", 12" (DN 150, 200, 250, 300)
Class 150; 300 (PN 10, 16, 25, 40)

TÜV
INSPECTOR
Mastrogiacomo Simone

CERTIFICATION DATE
29/08/13



TÜV Italia s.r.l. - TÜV SÜD Group