



Italia

Scegli la certezza.  
Aggiungi valore.

## FIRE SAFE CERTIFICATE

CERTIFICATE NUMBER: FS-063579-451

CLIENT: OMAL  
ADDRESS: Via Ponte Nuovo, 11 25050 Rodengo Saiano (BS)- Italy

REPORT NUMBER: 20

SCOPE OF REPORT: Fire Safe test carried out according to: **ISO 10497 Third Edition February 2010 and API 607 Sixth Edition September 2010**

max BAR: 14,3 Bar

max °C: +876°C

QUALIFIED VALVE: Size: 6"  
Rating Class: 150  
Drawing N°: Y\_3242  
Type: TRUNNION BALL VALVE SPLIT BODY

RANGE AND TYPE OF VALVES COVERED: NPS 6"; 8"; 10"; 12" (DN 150, 200, 250, 300)  
Class 150; 300 (PN 10, 16, 25, 40)

TÜV  
INSPECTOR  
Mastrogiacomo Simone

CERTIFICATION DATE  
21/07/2014

MANAGEMENT INSPECTION  
SERVICE  
Frecchiami Mauro

	<input type="checkbox"/> Review
	<input checked="" type="checkbox"/> Witness
Date: 21/07/14	Name: