



Italia

Scegli la certezza.  
Aggiungi valore.

## FIRE SAFE CERTIFICATE

CERTIFICATE NUMBER: FS-063579-584

CLIENT: OMAL  
ADDRESS: Via Ponte Nuovo, 11 25050 Rodengo Saiano (BS)- Italy

REPORT NUMBER: 33

SCOPE OF REPORT: Fire Safe test carried out according to: **ISO 10497 Third Edition February 2010 and API 607 Sixth Edition September 2010**

max BAR: **186,2 Bar**

max °C: **+913°C**

QUALIFIED VALVE: Size: 2"  
Rating Class: 1500  
Drawing N°: Y\_4468  
Type: TRUNNION BALL VALVE SPLIT BODY

RANGE AND TYPE OF VALVES COVERED: NPS 2" and below 2.1/2", 3", 4" (DN 50 and below 65, 80, 100)  
CLASS 1500, 2500 (PN 260, 420)

TÜV  
INSPECTOR  
Mastrogiacomo Simone

CERTIFICATION DATE  
25/05/2015

MANAGEMENT INSPECTION  
SERVICE  
Frecchiamini Mauro

	<input type="checkbox"/> Review
	<input checked="" type="checkbox"/> Witness
Date: 25/05/15	Name: .....

